

nature of the region surrounding the proposed site. Data on the vibratory ground motion, tectonic surface deformation, nontectonic deformation, earthquake recurrence rates, fault geometry and slip rates, site foundation material, and seismically induced floods and water waves must be obtained by reviewing pertinent literature and carrying out field investigations. However, each applicant shall investigate all geologic and seismic factors (for example, volcanic activity) that may affect the design and operation of the proposed ISFSI or MRS facility irrespective of whether these factors are explicitly included in this section.

(2) *Geologic and seismic siting factors.* The geologic and seismic siting factors considered for design must include a determination of the DE for the site, the potential for surface tectonic and nontectonic deformations, the design bases for seismically induced floods and water waves, and other design conditions as stated in paragraph (f)(2)(iv) of this section.

(i) Determination of the Design Earthquake Ground Motion (DE). The DE for the site is characterized by both horizontal and vertical free-field ground motion response spectra at the free ground surface. In view of the limited data available on vibratory ground motions for strong earthquakes, it usually will be appropriate that the design response spectra be smoothed spectra. The DE for the site is determined considering the results of the investigations required by paragraph (f)(1) of this section. Uncertainties are inherent in these estimates and must be addressed through an appropriate analysis, such as a probabilistic seismic hazard analysis (PSHA) or suitable sensitivity analyses.

(ii) Determination of the potential for surface tectonic and nontectonic deformations. Sufficient geological, seismological, and geophysical data must be provided to clearly establish if there is a potential for surface deformation.

(iii) Determination of design bases for seismically induced floods and water waves. The size of seismically induced floods and water waves that could affect a site from either locally

or distantly generated seismic activity must be determined.

(iv) Determination of siting factors for other design conditions. Siting factors for other design conditions that must be evaluated include soil and rock stability, liquefaction potential, and natural and artificial slope stability. Each applicant shall evaluate all siting factors and potential causes of failure, such as, the physical properties of the materials underlying the site, ground disruption, and the effects of vibratory ground motion that may affect the design and operation of the proposed ISFSI or MRS.

(3) Regardless of the results of the investigations anywhere in the continental U.S., the DE must have a value for the horizontal ground motion of no less than 0.10 g with the appropriate response spectrum.

[68 FR 54159, Sept. 16, 2003]

§ 72.104 Criteria for radioactive materials in effluents and direct radiation from an ISFSI or MRS.

(a) During normal operations and anticipated occurrences, the annual dose equivalent to any real individual who is located beyond the controlled area must not exceed 0.25 mSv (25 mrem) to the whole body, 0.75 mSv (75 mrem) to the thyroid and 0.25 mSv (25 mrem) to any other critical organ as a result of exposure to:

(1) Planned discharges of radioactive materials, radon and its decay products excepted, to the general environment,

(2) Direct radiation from ISFSI or MRS operations, and

(3) Any other radiation from uranium fuel cycle operations within the region.

(b) Operational restrictions must be established to meet as low as is reasonably achievable objectives for radioactive materials in effluents and direct radiation levels associated with ISFSI or MRS operations.

(c) Operational limits must be established for radioactive materials in effluents and direct radiation levels associated with ISFSI or MRS operations to meet the limits given in paragraph (a) of this section.

[53 FR 31658, Aug. 19, 1988, as amended at 63 FR 54562, Oct. 13, 1998]